

CERTIFICATION

IPI/EXT/TR/XIX/L-031

- 1) SUBJECT : *Fire-Off C-101 Lot No SA1902792 & Fire-Off AF-100 Lot No SC-1902019*
- 2) SAMPLE : *4 Kg Fire-Off C-101 & 3 cartridges Fire-Off AF-100*
- 3) CLIENT : *Blue Label Co. Ltd.*
- 4) TESTING METHOD
: *ASTM E-119*
: *ASTM E84*
- 5) CONCLUSION & CERTIFICATION

based on the testing performed by the institute, Indonesia Paint Institute certify "Fire-Off C-101 & Fire-Off AF-100" complies to ASTM E84 "Class A" and ASTM E119 "2.5 hours fire rating" .

This conclusion and certification is valid for the tested samples given for 2 years

Indonesia Paint Institute

Tangerang, December 28th 2019



By:

Name: Dr. Ningsih Setiabudi M.Sc

Title: Director